CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. Page 1 of 1 7120-1130:229

CATEGORY: **Annunciators**

LISTEE: Honeywell International Inc. 1500 W. Dundee Road, Arlington Heights, IL 60004-1472

Contact: Bob Hodgson (847) 797-4403 FAX (847) 797-3664

DESIGN: Model XLS-LCD80F remote fire annunciator. Unit is a compact 80-character, backlit LCD

fire annunciator. Refer to listee's data sheet for additional detailed product description

and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating, and UL label.

APPROVAL: Listed as an annunciator for use separately listed compatible fire alarm control units. Refer to

listee's Installation Instruction Manual for details.

XLF: 7120-0028:209

09-09-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 22, 2004 Listing Expires June 30, 2005 Date Issued:

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager